

Fire Shutter & Security Grills

1. A fire shutter is indicated at the Parts Manager # 137, we will need a size for this counter shutter.

EDR Response: Parts Manager window is type CB1-J: 3' W x 4' T. The fire shutter at the customer lounge window is type CB1-I 20'Wx4'T.

2. There are two security grilles located at Retail Parts & Cashier, can we get sizes and perhaps a specification for the grilles?

EDR Response: Those openings are approximately 5'Wx6'T. Refer to Sheet A600 in Addendum 01 for the specification information on these.