

## PEMB RFIs

1. What is the gauge specified for Interior & Exterior Panels?

**Steel Thickness: 24 gauge, minimum**

2. What are the colors specified for roof and wall panels?

**Finish: Fluoropolymer Coating System: Manufacturer's standard multi-coat thermocured coating system, including minimum 70 percent fluoropolymer color topcoat with minimum total dry film thickness of 0.9 mil; color and gloss to be selected by Architect from Manufacturer's standard colors.**